

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lisem 129/2, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1210449

Product: Electric cables with PVC thermoplastic insulation and sheath for fixed installation

Type: CYKY

Rating: (2 – 5) x (1,5 – 16) mm²; 450/750 V

Ordering firm: ALVES ENERJI KABLO URETIM SAN DIS TIC AS.
Fatih Mahallaesi Karatay Cad No. 6, Kahramankazan/Ankara, Turkey

Manufacturer: ALVES ENERJI KABLO URETIM SAN DIS TIC AS.
Fatih Mahallaesi Karatay Cad No. 6, Kahramankazan/Ankara, Turkey

Factories: ALVES ENERJI KABLO URETIM SAN DIS TIC AS.
Fatih Mahallaesi Karatay Cad No. 6, Kahramankazan/Ankara, Turkey

Trade mark:

The test results are stated in the test-report No.: 211055-01/01 of: 28.07.2021

A sample of the product was found to be in conformity with:
ČSN 34 7411:14

Other data:

Certificate was issued on the basis of fulfillment of requirements of the "EZÚ certificate" certification scheme and on the basis of agreement No. 211055 between the client and the Electrotechnical Testing Institute.

Compliance of the product with mentioned standards and regulations ensures compliance of the product with essential requirements of Government Order No. 118/2016 Sb. (2014/35/EU) as amended, and the certificate may be used as a supporting document for the EU Declaration of Conformity under Act No. 90/2016 Coll., on Conformity Assessment of Products When Made Available on the Market, as amended.

The validity of the certificate is limited to: 31.07.2024

02.08.2021

Prague

Mgr. Miroslav Sedláček
Head of Certification Body



Stamp



211055-01